




SITE UTILITIES

1. CONTRACTOR SHALL FURNISH ALL MATERIALS, LABOR, EQUIPMENT, TOOLS, AND SUPPLIES REQUIRED FOR THE COMPLETE CONSTRUCTION OF THE PROPOSED IMPROVEMENTS. THE CONTRACTOR SHALL PROTECT ALL EXISTING IMPROVEMENTS AND NEWLY CONSTRUCTED FACILITIES FROM DAMAGE DURING THE COURSE OF THE PROJECT. CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR THE REPAIR OR REPLACEMENT, AND COST, OF ANY IMPROVEMENTS, INCLUDING TREES, DAMAGED WHILE THE SITE IS UNDER HIS CONTROL, WHETHER WORK IS ONGOING OR NOT.
2. ALL TRENCHES SHALL BE BACKFILLED AND COMPACTED IN ACCORDANCE WITH THE RECOMMENDATIONS FOR EARTHWORK CONTAINED IN THE PROJECT'S GEOTECHNICAL INVESTIGATION REPORT.
3. ALL STORM SEWER LINES INSTALLED WITHIN PUBLIC RIGHTS-OF-WAY OR EASEMENTS SHALL BE CONSTRUCTED IN ACCORDANCE WITH A.) NORTH CENTRAL TEXAS STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (COG SPECS.), B.) COG STANDARD DRAWINGS FOR PUBLIC WORKS CONSTRUCTION, C.) TOWN OF ADDISON CODE, AND SUBDIVISIONS AND LAND DEVELOPMENT REGULATIONS, D.) RULE AND REGULATIONS FOR PUBLIC WATER SYSTEMS ESTABLISHED BY THE TEXAS NATURAL RESOURCES CONSERVATION COMMISSION (TNRCC).
4. CONNECTION TO THE EXISTING CURB INLET SHALL BE MADE BY REMOVING A SECTION OF THE INLET WALL EQUAL TO THE OUTSIDE DIAMETER OF THE PIPE PLUS 6 INCHES. THE NEW PIEP SHALL BE INSTALLED FLUSH WITH THE INSIDE FACE OF THE INLET WALL. THE ANNULUS SPACE SHALL BE PACKED WITH MINIMUM 2500 PSI CONCRETE, AND A CONCRETE PIPE COLLAR PLACED AT THE OUTSIDE FACE OF THE INLET.
5. THE SITE UTILITY CONTRACTOR SHALL COORDINATE THE LOCATIONS OF ALL BUILDING SERVICE LATERAL TIE-IN POINTS WITH THE BUILDING PLUMBING CONTRACTOR.
6. CONTRACTOR SHALL MAINTAIN DRAINAGE TO ALL STORM DRAIN INLETS AT ALL TIMES. STORMWATER POLLUTION PREVENTION MEASURES SHALL BE INSTALLED AS NECESSARY TO PREVENT SEDIMENT RUNOFF IN TO THE STORM DRAIN SYSTEM.
7. ALL UTILITY STATIONING AND COORDINATES ARE TO CENTERLINE OF PIPE OR INSIDE FACE OF INLET UNLESS NOTED OTHERWISE.
8. ALL UTILITY CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE TOWN OF ADDISON STANDARD CONSTRUCTION DETAILS AND SPECIFICATIONS.
9. CONTRACTOR SHALL VERIFY ALL UTILITY TIE-IN POINTS PRIOR TO BEGINNING UTILITY CONSTRUCTION. ALL DISCREPANCIES BETWEEN FOUND FIELD CONDITIONS AND THESE DRAWINGS SHALL BE PROMPTLY REPORTED TO THE ENGINEER AND OWNER'S REPRESENTATIVE. NO UTILITY CONSTRUCTION SHALL OCCUR UNTIL THE DISCREPANCIES ARE RESOLVED.

CAUTION !!!
EXISTING UTILITIES
 EXISTING PUBLIC AND FRANCHISE UTILITY LINE CROSSINGS IN THIS AREA. CONTRACTOR SHALL EXERCISE EXTREME CAUTION WHILE EXCAVATING AND WORKING IN THIS AREA. EXISTING UTILITY CROSSINGS SHALL BE EXPOSED AND ALIGNMENTS VERIFIED PRIOR TO BEGINNING NEW UTILITY CONSTRUCTION. CONTRACTOR SHALL EMPLOY ANY NECESSARY METHOD OF EXCAVATION, INCLUDING HAND EXCAVATION AND/OR "AIR-VAC", WHICH MAY BE JUSTIFIED TO INSURE NO DAMAGE TO THESE FACILITIES. CONTRACTOR SHALL TAKE ALL AVAILABLE PRECAUTIONS WHILE WORKING IN THIS AREA.



NKR ENGINEERING GROUP, INC.
 4004 BELT LINE RD
 SUITE 210
 ADDISON, TEXAS 75001
 PH: 972.818.6305
 FAX: 972.818.6306


V. MENON RESIDENCE
 14523 WINNWOOD ROAD
 LOT 3, BLOCK 8171
 MENON ADDITION
 CITY OF ADDISON, DALLAS COUNTY, TEXAS

STATE OF TEXAS
 THOMAS J. KNICKER
 67731
 REGISTERED PROFESSIONAL ENGINEER
Thomas J. Knicker
 9/19/05

CONSTRUCTION STORM DRAIN PLAN
 Issue Date: 07APR05
 Project No.: 8804
 Drawn By: TJK
 Reviewed By: TJK
 SHEET NUMBER:


C2.0

VOTEX SURVEYING COMPANY 4548 Tuscan Drive Plano, Texas 75093-7042 Ph. (972) 964-0858



LEGEND
 1/2" I.R.S. IRON ROD SET WITH YELLOW CAP STAMPED "VOTEX R.P.L.S. #4813"
 1/2" I.R.F. IRON ROD FOUND
 "X" FND. "X" CUT FOUND IN CONCRETE

BEARING SOURCE:
 THE WEST RIGHT-OF-WAY LINE OF WINNWOOD ROAD (S 00°09'30" E), ACCORDING TO THE DEED.



LOT 8

LOT 7 BLOCK 1

LOT 6

LOT 4 BLOCK 8171
 CHARLES E. PAINTER SUBDIVISION VOL. 78162, PG. 3339 P.R.D.C.T.
 WILLIAM E. ROBBINS VOL. 96091, PG. 2469 D.R.D.C.T.

LOT 3 BLOCK 8171
 34,147 SQ. FT. 0.7839 ACRES
 KARIM L. ASSOUD VOL. 94179, PG. 0583 D.R.D.C.T.
 CHARLES K. HOWARD SUBDIVISION VOL. 72158, PG. 51

LOT 2 BLOCK 8171

WINNWOOD ROAD
 (60' R.O.W.)
 S 00°09'30" E 178.85' REFERENCE BEARING

OWNER
 VENUGOPAL B. MENON
 3537 LAKEBROOK DRIVE
 PLANO, TEXAS 75093

SURVEYOR
 VOTEX SURVEYING COMPANY
 CONTACT: DENNIS VOTE
 4548 TUSCANY DRIVE
 PLANO, TEXAS 75093-7042
 PH. (972) 964-0858

SURVEYOR'S CERTIFICATE
 I, DENNIS D. VOTE, A REGISTERED PROFESSIONAL LAND SURVEYOR IN THE STATE OF TEXAS, DO HEREBY CERTIFY THAT I PREPARED THIS PLAT FROM AN ACTUAL ON THE GROUND SURVEY OF THE LAND AND THAT THE MONUMENTS SHOWN THEREON WERE FOUND AND/OR PLACED UNDER MY PERSONAL SUPERVISION IN ACCORDANCE WITH THE PLATTING RULES AND REGULATIONS OF THE CITY PLANNING COMMISSION OF THE TOWN OF ADDISON, TEXAS.

EXECUTED THIS _____ DAY OF _____, 2004.

DENNIS D. VOTE, REGISTERED PROFESSIONAL LAND SURVEYOR, NO. 4813
PRELIMINARY
 RELEASED DECEMBER 27, 2004 FOR REVIEW PURPOSES ONLY.
 THIS DOCUMENT SHALL NOT BE RECORDED FOR ANY PURPOSE

STATE OF TEXAS:
 COUNTY OF COLLIN:

BEFORE ME, THE UNDERSIGNED AUTHORITY, A NOTARY PUBLIC IN AND FOR SAID COUNTY AND STATE, ON THIS DAY PERSONALLY APPEARED DENNIS D. VOTE, KNOWN TO ME TO BE THE PERSON OR PERSONS WHOSE NAME IS SUBSCRIBED TO THE FOREGOING INSTRUMENT, AND ACKNOWLEDGED TO ME THAT HE/SHE EXECUTED THE SAME IN THE CAPACITY HEREIN STATED AND THE ACT AND DEED OF SAID COMPANY.

GIVEN UNDER MY HAND AND SEAL OF OFFICE, THIS _____ DAY OF _____, 2004.

NOTARY PUBLIC IN AND FOR COLLIN COUNTY, TEXAS

CONSTRUCTION SET
 ISSUED BY
 TOWN OF ADDISON
 PUBLIC WORKS DEPARTMENT

NAME: *Steve Chatham* DATE: *4/22/05*

FINAL PLAT
MENON ADDITION
LOT 3, BLOCK 8171
0.7839 ACRES
OUT OF THE
ALLEN BLEDSOE SURVEY, ABSTRACT NO. 157
TOWN OF ADDISON, DALLAS COUNTY, TEXAS

SCALE: 1"=20' DATE: MARCH 7, 2005

PROJECT NO. 24049

OWNER'S CERTIFICATION
 STATE OF TEXAS:
 COUNTY OF DALLAS:
 WHEREAS Venugopal B. Menon is the owner of a tract of land situated in the ALLEN BLEDSOE SURVEY, ABSTRACT NO. 157, Town of Addison, Dallas County, Texas according to the deed recorded in Volume 2004188, Page 6202, Deed Records, Dallas County Texas (D.R.D.C.T.) and being more particularly described as follows:
 BEGINNING at a 1/2 inch iron rod found in the westerly right-of-way line of Winnwood Road (a 60' R.O.W.), being the southeast corner of this tract (known as Lot 3, Block 8171), and also being the northeast corner of Lot 2, Block 8171, of the Charles K. Howard Subdivision, an addition to the Town of Addison, according to the plat thereof recorded in Volume 72158, Page 51, Map Records, Dallas County, Texas (M.R.D.C.T.);

THENCE S 85 deg. 03 min. 18 sec. W, along the north line of said Lot 2, a distance of 193.04 feet to the south corner of a brick fence column for corner, and being in the east line Lot 7, Block 1 of Bellbrook Estates, an addition to the Town of Addison, according to the plat thereof recorded in Volume 86234, Page 4696, M.R.D.C.T.;

THENCE N 00 deg. 45 min. 45 sec. E, along the east line of said Lot 7 and along the east line of Lot 8 of said Block 1, a distance of 179.11 feet to a point in fence column for corner, being in the south line of Lot 4, Block 8171, of the Charles E. Painter, Subdivision, an addition to the Town of Addison, according to the plat thereof, recorded in Volume 78162, Page 3339, M.R.D.C.T.;

THENCE N 85 deg. 03 min. 14 sec. E, along the south line of said Lot 4, a distance of 190.16 feet to a 1/2 inch iron rod found for corner in the westerly right-of-way line of said Winnwood Road;

THENCE S 00 deg. 09 min. 30 sec. E, along the westerly right-of-way line of said Winnwood Road, a distance of 178.85 feet to the POINT OF BEGINNING and containing 34,147 sq. ft. or 0.7839 acres of land.

OWNER'S DEDICATION
 NOW, THEREFORE, KNOW ALL MEN BY THESE PRESENT:

THAT Venugopal B. Menon, does hereby adopt this plat, designating the herein above described property as **MENON ADDITION**, an addition to the Town of Addison, Dallas County, Texas. The easements shown thereon are hereby reserved for the purposes indicated. The utility and fire lane easements shall be open to the public, fire and police units, garbage and rubbish collection agencies, and all public and private utilities for each particular use. The maintenance of paving on the utility and fire lane easements is the responsibility of the property owner. No buildings, fences, trees, shrubs or other improvements or growths shall be constructed, reconstructed, or placed upon, over or across the easements as shown. Said easements being hereby reserved for the mutual use and accommodation of all public utilities using or desiring to use same. All and any public utility shall have the right to remove and keep removed all or parts of any building, fences, trees, shrubs or other improvements or growths which in any way may endanger or interfere with the construction, maintenance or efficiency of its respective system on the easements and all public utilities shall at all times have the full right of ingress and egress to or from and upon said easements for the purpose of constructing, reconstructing, inspecting, patrolling, maintaining and adding to or removing all or parts of its respective systems without the necessity at any time of procuring the permission of anyone. (Any public utility shall have the right of ingress and egress to private property for the purpose of reading meters and any maintenance and service required or ordinarily performed by that utility).

Water main and wastewater easements shall also include additional area of working space for construction and maintenance the systems. Additional easement area is also conveyed for the installation and maintenance of manholes, cleanouts, fire hydrants, water services and wastewater services from the main to the curb or pavement line, and description of such additional easements herein granted shall be determined by their location as installed.

This plat approved subject to all platting ordinances, rules, regulations and resolutions of the Town of Addison, Texas.

WITNESS my hand at Addison, Texas, this the _____ day of _____, 2004.

By: _____
 Venugopal B. Menon

STATE OF TEXAS:
 COUNTY OF DALLAS:

BEFORE me, the undersigned authority, a Notary Public in and for said County and State, on this day personally appeared Venugopal B. Menon, known to me to be the person or persons whose name is subscribed to the foregoing instrument, and acknowledged to me that he executed the same in the capacity herein stated and the act and deed of said company.

GIVEN UNDER MY HAND AND SEAL OF OFFICE, this _____ day of _____, 2004.

Notary Public in and for Dallas County, Texas


GENERAL NOTES

1. CAUTION!!! - UNDERGROUND UTILITIES: LOCATION OF EXISTING UTILITIES AND UNDERGROUND FACILITIES SHOWN ON THESE PLANS ARE APPROXIMATE AND ARE BASED ON FIELD SURVEYS AND AVAILABLE RECORD DRAWINGS. CONTRACTOR SHALL FIELD VERIFY THE HORIZONTAL AND VERTICAL ALIGNMENT OF ALL EXISTING IMPROVEMENTS, WHETHER SHOWN OR NOT, PRIOR TO BEGINNING WORK. THE CONTRACTOR SHALL NOTIFY THE ENGINEER AT LEAST 48 HOURS PRIOR TO BEGINNING WORK AFFECTED BY SAID UTILITIES, OF ANY AND ALL CONFLICTS BETWEEN THE EXISTING UTILITIES AND THE PROPOSED IMPROVEMENTS.
2. TOPOGRAPHIC SURVEY OF EXISTING CONDITIONS AND SURVEY CONTROL INFORMATION HAVE BEEN PROVIDED BY THE OWNER. CONTRACTOR SHALL COORDINATE WITH THE OWNER'S SURVEYOR TO IDENTIFY BENCHMARKS FOR THE PROJECT.
3. CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING IMPROVEMENTS, INCLUDING UTILITIES, PAVEMENT, AND LANDSCAPING WITHIN OR ADJACENT TO THE AREA OF WORK DURING THE COURSE OF THE PROJECT. CONTRACTOR SHALL REPAIR OR REPLACE ANY DAMAGED FACILITIES OR IMPROVEMENTS DAMAGED DURING THE COURSE OF THE PROJECT AT NO ADDITIONAL EXPENSE TO THE OWNER.
4. CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING AND MEETING THE REQUIREMENTS FOR ALL PERMITS REQUIRED BY THE TOWN OF ADDISON PRIOR TO BEGINNING WORK.
5. CONTRACTOR SHALL MAINTAIN DRAINAGE AT ALL TIMES. PONDING OF WATER ONSITE OR ADJACENT TO THE PROJECT AREA WILL NOT BE ALLOWED.
6. ALL MATERIALS REMOVED AS PART OF THE PROJECT SHALL BECOME THE PROPERTY OF THE CONTRACTOR (EXCEPT AS NOTED ON THE PLANS) AND SHALL BE DISPOSED OFFSITE AT HIS EXPENSE. NO STORAGE OR STOCKPILING OF REMOVED MATERIALS WILL BE ALLOWED ONSITE.
7. ALL GRADES SHOWN ARE TO TOP OF PAVEMENT OR FINISHED GRADE. CONTRACTOR SHALL ADJUST SUBGRADE ELEVATION AS NEEDED TO ACCOMMODATE PAVEMENT THICKNESSES AND TOPSOIL REFERENCE PROJECT SPECIFICATIONS FOR TOPSOILING REQUIREMENTS.
8. CONTRACTOR SHALL INSTITUTE NECESSARY MEASURES TO CONTROL SEDIMENT RUNOFF DURING THE CONSTRUCTION OF THIS PROJECT. ALL EROSION CONTROL MEASURES AND NPDES NOTIFICATION/PERMITTING SHALL BE IN ACCORDANCE WITH THE TOWN OF ADDISON REQUIREMENTS.

CAUTION !!!
EXISTING UTILITIES
 EXISTING PUBLIC AND FRANCHISE UTILITY LINE CROSSINGS IN THIS AREA. CONTRACTOR SHALL EXERCISE EXTREME CAUTION WHILE EXCAVATING AND WORKING IN THIS AREA. EXISTING UTILITY CROSSINGS SHALL BE EXPOSED AND ALIGNMENTS VERIFIED PRIOR TO BEGINNING NEW UTILITY CONSTRUCTION. CONTRACTOR SHALL EMPLOY ANY NECESSARY METHOD OF EXCAVATION, INCLUDING HAND EXCAVATION AND/OR "AIR-VAC", WHICH MAY BE JUSTIFIED TO INSURE NO DAMAGE TO THESE FACILITIES. CONTRACTOR SHALL TAKE ALL AVAILABLE PRECAUTIONS WHILE WORKING IN THIS AREA.

LEGEND

- FLOW DIRECTION
- 640 --- EXISTING CONTOUR
- 640 — FINISHED GRADE CONTOUR
- 640.27 PROPOSED SPOT ELEVATION
- B-3
1.249.8 D.A. DESIGNATION AREA(ac.)/Q(100)
- --- PROPOSED MINOR DRAINAGE DIVIDE
- — — — PROPOSED MAJOR DRAINAGE DIVIDE
- ➔ PT OF CONCENTRATION



DRAINAGE CALCULATION

RATIONAL METHOD: $Q=C*I*A$

Q= DRAINAGE FLOW IN CUBIC FEET/SECOND
 C= 0.60 FOR RESIDENTIAL
 I= 8.74 IN/HR FOR 100 YR STORM INTENSITY
 A= ACREAGE OF DRAINAGE AREA
 t= 10 MINUTE TIME OF CONCENTRATION

NOTES:

1. PROPOSED STORM DRAIN IMPROVEMENTS ARE DESIGNED IN ACCORDANCE WITH THE TOWN OF ADDISON STANDARDS.
2. TOPOGRAPHIC SURVEY OF EXISTING CONDITIONS AND SURVEY CONTROL INFORMATION HAS BEEN DEVELOPED AND PROVIDED BY THE OWNER FOR USE ON THIS PROJECT. DESIGN OF PROPOSED IMPROVEMENTS ARE BASED ON THIS INFORMATION.
3. OFFSITE DRAINAGE AREAS ARE BASED ON THE BELLBROOK ESTATES FINAL PLAT. AVAILABLE DRAINAGE PLANS FOR HAMPTON COURT AND BELLBROOK DRIVE, IN CONJUNCTION WITH FIELD OBSERVATIONS, WERE USED TO ESTIMATE THE DRAINAGE AREA CONTRIBUTING TO FLOWS ENTERING THE SUBJECT PROPERTY. THE PROPOSED DRAINAGE IMPROVEMENTS ACCOMMODATE SURFACE RUNOFF FROM BELLBROOK ESTATES, LOTS 6 AND 7, AND THE RESIDENTIAL LOTS LOCATED AT 5505, 5535, AND 5545 CELESTIAL RD. TOTAL DRAINAGE AREA IS 2.22 ACRES.

APPROVED
 SIGNED *Steve Chatham* DATE 4/19/05
 TITLE _____
 TOWN OF ADDISON
 PUBLIC WORKS DEPARTMENT

| REV. | DESCRIPTION | DATE |
|------|---------------------------|---------|
| 1 | INCORPORATE TOWN COMMENTS | 19APR05 |


NKR ENGINEERING GROUP, INC.
 4004 BELT LINE RD
 SUITE 210
 ADDISON, TEXAS 75001
 PH: 972.818.6305
 FAX: 972.818.6306

V. MENON RESIDENCE
 14523 WINWOOD ROAD
 LOT 3, BLOCK 8171
 MENON ADDITION
 CITY OF ADDISON, DALLAS COUNTY, TEXAS

STATE OF TEXAS
 THOMAS J. KNICKER
 67731
 REGISTERED PROFESSIONAL ENGINEER
 4/19/05


CONSTRUCTION
DRAINAGE AREA MAP GRADING PLAN
 Issue Date: 07APR05
 Project No.: 8804
 Drawn By: TJK
 Reviewed By: TJK
 SHEET NUMBER:

C1.0
 SHEET 1 OF 2




19"Ø C.I. Cover

Weight - 55 Lbs.
Item# - 7102500



"Y" Top w/ Frame

Weight - 1725 Lbs.
Item# - 1207260



Bottom

Weight - See Table
Item# - See Table

SCALE: NONE



JB-330-Y

**3'-0" x 3'-0" I.D.
"Y" Inlet**


FILE NAME: 260DJJB-330-Y_F.dwg

ISSUE DATE: January, 2003


www.oldcastleprecast.com

1100 Heritage Parkway, Mansfield, Texas 76063
Phone: 817.453.1054 Fax: 817.453.4007


Copyright © 2002 Oldcastle Precast, Inc.



PLAN VIEW



SECTION A-A



ELEVATION B-B

SCALE: 1/2"=1'-0"

SPECIFICATIONS:

1. Concrete: Has a Design Strength of 5,000 psi at 28 Days.
2. Steel Reinforcement: ASTM A-615, Grade 60 or ASTM A-497 Welded Wire Fabric.
3. Loading: Designed for H2O Loading.
4. C.I. Castings: ASTMA-48, Class 30/35.

GENERAL NOTES:

1. Different Height of Bodies are Available by Request.
2. Other Frame and Covers Also Available.

| Bottom Section | | | |
|----------------|-----|-----------|---------|
| A | B | Weight | Item # |
| 12" | 18" | 2250 Lbs. | 1203520 |
| 24" | 30" | 3300 Lbs. | 1203660 |
| 30" | 36" | 3825 Lbs. | 1203740 |
| 36" | 42" | 4350 Lbs. | 1203780 |
| 42" | 48" | 4875 Lbs. | 1203880 |
| 48" | 54" | 5400 Lbs. | 1203960 |
| 60" | 66" | 6450 Lbs. | 1204060 |



1100 Heritage Parkway, Mansfield, Texas 76063
Phone: 817.453.1054 Fax: 817.453.4007

JB-330-Y


FILE NAME: 260DJJB-330-Y_B.dwg

ISSUE DATE: January, 2003

www.oldcastleprecast.com


**3'-0" x 3'-0" I.D.
"Y" Inlet**

Copyright © 2002 Oldcastle Precast, Inc.



SECTION "A-A"

N.T.S.



PLAN OF TOP SLAB

N.T.S.

| INLET SIZE | T | W |
|------------|----|-------|
| 2' SQUARE | 7" | 2'-0" |
| 4' SQUARE | 7" | 4'-0" |
| 5' SQUARE | 8" | 5'-0" |
| 6' SQUARE | 9" | 6'-0" |

NOTES:

1. MATERIAL AND WORKMANSHIP SHALL CONFORM WITH THE REQUIREMENTS OF NCTCOG STANDARD SPECIFICATIONS FOR STANDARD CONCRETE MANHOLES. MINIMUM CLASS "A" CONCRETE.
2. LAYERS OF REINFORCING STEEL NEAREST THE INTERIOR AND EXTERIOR SURFACES SHALL HAVE A COVER OF 2" TO THE CENTER OF BARS, UNLESS OTHERWISE NOTED.
3. FOR DETAILS OF REINFORCING OF LOWER PORTIONS OF INLET SEE APPROPRIATE SQUARE MANHOLE DETAILS.
4. DEPTH OF DROP INLET FROM FINISHED GRADE TO FLOW LINE OF INLET IS VARIABLE. APPROXIMATE DEPTH WILL BE SHOWN ON PLANS AT LOCATION OF INLET.
5. ALL STANDARD DROP INLETS SHALL HAVE ONE OPENING ON EACH SIDE UNLESS OTHERWISE SHOWN ON PLANS.
6. DECK MAY BE REINFORCED SAME AS 4' SQUARE MANHOLE.

DROP INLET

2'. 4'. 5' OR 6' SQUARE

North Central Texas Council of Governments



STANDARD SPECIFICATION REFERENCE

DATE STANDARD DRAWING NO.