



**PUBLIC WORKS DEPARTMENT**  
Post Office Box 9010 Addison, Texas 75001-9010

**(972) 450-2871 FAX (972)450-2837**  
**16801 Westgrove**

September 19, 2007

Mr. Michael Daniel, P.E.  
Nathan D. Maier Consulting Engineers, Inc.  
Two Northpark  
8080 Park Lane, Suite 600  
Dallas, Texas 75231

Re: Plan Review  
Sidewalk Construction Plan for Trinity Christian Academy

Dear Mr. Daniel:

The Town of Addison has completed the review of the above referenced plans and has the following comments:

1. Please draw the crosswalk in accordance with the traffic study. Indicate that it is to be constructed of thermoplastic.
2. Please indicate the location of the signs.
3. Please revise the accessible ramp as indicated.
4. Please add a barrier free ramp at the end of the sidewalk at the existing drive. The ramp can be similar in configuration to the detail shown on the plans.
5. Place the details shown in the included specification for concrete sidewalks on the plan.
6. Callout "place 1/2" bituminous expansion joint material between the proposed sidewalk and the existing screening wall. Depth of the material shall be sufficient to prevent contact between the proposed sidewalk and the existing screening wall."

Please address all comments and return three sets of plans along with the markups. If you have any questions, please feel free to contact me.

Sincerely,  
**TOWN OF ADDISON**

Clay Barnett, P.E.  
Assistant Town Engineer