

Freeman, Steven

---

From: Jenny Prazak <JPrazak@cobbhendley.com>  
Sent: Monday, October 21, 2019 3:12 PM  
To: Freeman, Steven  
Cc: Olga Chernomorets; Acevedo, Elioth; Dave Wilde; Wilson Kakembo; Joel Jenkinson; Bill Dyer; MRMcAnally@GarverUSA.com; Andrews, Sara C.; Jonathan Hitchcock  
Subject: RE: Galaxy FBO Civil Review 2  
  
Categories: External

Steven,

The oil/water separator at the fuel farm can continue to discharge into the storm system and does not need to be re-routed to the sanitary sewer.


Thanks for your patience while we made this determination.

**JENNY PRAZAK, P.E.**

Associate | Project Manager

office 972.335.3214  
fax 972.335.3202

2801 Network Boulevard, Suite 800 | Frisco, TX 75034  
cobbhendley.com | TBPE No. F-274 | TBPLS No. 10046702



---

From: Jenny Prazak  
Sent: Tuesday, October 15, 2019 2:24 PM  
To: Freeman, Steven <steven.freeman@kimley-horn.com>  
Cc: Olga Chernomorets <ochernomorets@addisontx.gov>; Acevedo, Elioth <Elioth.Acevedo@kimley-horn.com>; Dave Wilde <dwilde@addisontx.gov>; Wilson Kakembo <wkakembo@addisontx.gov>; Joel Jenkinson <joel.jenkinson@addisonairport.net>; Bill Dyer <bdyer@samimgmt.com>; MRMcAnally@GarverUSA.com; Andrews, Sara C. <SCAndrews@GarverUSA.com>; Jonathan Hitchcock <jhitchcock@blackforestventures.com>  
Subject: RE: Galaxy FBO Civil Review 2

Steven,

The public works & stormwater crews need to check one last item before I can say definitively. They're hoping to let me know by the end of the week, at which point I'll have an answer for you.

Thanks for your patience,

**JENNY PRAZAK, P.E.**

Associate | Project Manager

office 972.335.3214  
fax 972.335.3202

2801 Network Boulevard, Suite 800 | Frisco, TX 75034  
cobbhendley.com | TBPE No. F-274 | TBPLS No. 10046702