



- NOTES:
- 1 CONNECT TO EXISTING THREE-WAY SWITCH AT LOCATION SHOWN.
  - 2 ALL 2' x 4' FLUORESCENT LIGHT FIXTURES IN THIS ROOM/ AREA ARE RELOCATED EXISTING.
  - 3 REWIRE LIGHTING IN THIS ROOM TO CONTROL ALL LIGHTS FROM EXISTING SWITCH AT DOOR.
  - 4 TO EXISTING 120/240V, 1Ø, 3Ø PANEL IN ROOM 150, PROVIDE NEW 20A, 1P CIRCUIT BREAKER.
  - 5 TO NEXT AVAILABLE 20A, 1P CIRCUIT BREAKER IN EXISTING 120/240V, 1Ø, 3Ø PANEL IN WAREHOUSE.
  - 6 TO EXIST. EMERGENCY Ltg. CIRCUIT IN WAREHOUSE.
  - 7 ALL EXISTING LIGHT FIXTURES TO BE RE-USED SHALL BE CLEANED AND LEFT IN GOOD OPERATING CONDITION AFTER BEING INSTALLED IN NEW LOCATION. REPLACE LAMPS AND BALLASTS AS REQUIRED.
  - 8 TO SWITCH 'X'.

01 FIRST FLOOR PLAN- LIGHTING  
E2.2



**EDI ARCHITECTS, INC.**  
ARCHITECTURE PLANNING ENGINEERING INTERIOR DESIGN  
DALLAS, TEXAS 75201  
PHONE 754-1501 FAX 754-1502

**TOWN OF ADDISON**

**ADDITION TO PUBLIC WORKS SERVICE CENTER**  
Westgrove Road  
Addison, Texas

11 JUNE 86  
24 JULY 1986 - BID  
REV 07 1002 86

PROPERTY OF  
TOWN OF ADDISON  
E2.2

SHEETS  
JOB NO. 884-187