



NOTES:

- ① ALL RECEPTACLES IN THIS ROOM SHALL BE MOUNTED 54" A.F.F.
- ② LOCATE ON ROOF JOIST.
- ③ REMOVE ALL CONVENIENCE AND TELEPHONE OUTLETS IN THIS AREA UNLESS NOTED TO REMAIN. FIELD VERIFY EXISTING CONDITIONS.
- ④ EXISTING TO REMAIN.
- ⑤ TO NEXT AVAILABLE 20A, 1P CIRCUIT BREAKER IN EXISTING 120/240V, 1P, 3M PANEL. - SEE NOTE 9
- ⑥ 3 #10, 3/4" C. TO EXISTING 30A, 2P CIRCUIT BREAKER IN EXISTING 120/240V, 1P, 3M PANEL. - SEE NOTE 9
- ⑦ CONNECT TO EXISTING CIRCUIT AT EXISTING DEVICE SHOWN.
- ⑧ EXISTING FIRE ALARM CONTROL PANEL TO REMAIN.
- ⑨ EXISTING 120/240V, 1P, 3M PANEL TO REMAIN FOR POWER IN RE-MODELED OFFICE SPACE.
- ⑩ ALL RECEPTACLES IN THIS ROOM SHALL BE MOUNTED 44" A.F.F.
- ⑪ ALL RECEPTACLES IN THIS ROOM SHALL BE MOUNTED 34" A.F.F.
- ⑫ EXISTING 240V, 3 Ø, 200A M.L.O. PANEL TO REMAIN.
- ⑬ EXISTING 120/240V, 1Ø 3M 200A M.L.O. PANEL TO REMAIN.
- ⑭ EXISTING 120/240V, 1Ø, 3M M.L.O. PANEL BELOW 3Ø PANEL TO REMAIN.
- ⑮ EXISTING 120/240V, 3Ø, 4W 800A M.L.O. PANEL AND SERVICE TO BE REMOVED.
- ⑯ TO EXISTING PANEL (SEE NOTE 13) PROVIDE NEW 20A, 1P CIRCUIT BREAKER.
- ⑰ 3 #10, 3/4" C. TO EXISTING PANEL (SEE NOTE 13) PROVIDE NEW 30A, 2P CIRCUIT BREAKER.
- ⑱ RELOCATED AIR COMPRESSOR.
- ⑲ AIR COMPRESSOR TO BE RELOCATED.

01 FIRST FLOOR PLAN - POWER
E2.1 WF-T-F



EDI ARCHITECTS, INC.
ARCHITECTURE PLANNING INTERIOR DESIGN
AMERICAN BANK TOWER
SUITE 1000
AUSTIN, TEXAS 78701
512 / 488-8338

TOWN OF
ADDISON

**ADDITION TO
PUBLIC WORKS SERVICE CENTER**
Westgrove Road
Addison, Texas

DATE:
11 JUNE 88
24 JULY 1988 - BID
REV 17 10.07.88

SHEET NO. 01 OF 01
L.A. TOWN OF ADDISON
OF SHEETS